




# Attestation of Conformity

**Certificate No.:** 2488AP020130001  
**Equipment:** Photovoltaic (PV) and battery inverter  
**Brand Name:**   
**Test Model No.:** UHC-4KT-U2, UHC-5KT-U2, UHC-6KT-U2, UHC-8KT-U2,  
UHC-10KT-U2, UHC-12KT-U2, UHC-15KT-U2, UHC-20KT-U2  
**Applicant:** Upower Electric Co., Ltd  
Room 401, A Building Huafeng Intelligence Valley-Yuanshan Hi-Tech Park,  
No.62 Yinhe Road, He'ao Community, Yuanshan Street, Longgang District,  
Shenzhen, China  
**Report No.:** PVBE2402WDG0130-1

## Use in accordance with regulations:

Automatic disconnection device with three-phase mains surveillance in accordance with C10/11:2021 for photovoltaic systems with a three-phase parallel coupling via an inverter in the public mains supply. The automatic disconnection device is an integral part of the aforementioned inverter.

## Applied rules and standards

### EN 50549-1:2019

Requirements for generating plants to be connected in parallel with distribution networks - Part 1-1: Connection to a LV distribution network - Generating plants up to and including Type B

### C10/11:2021

Specific technical prescriptions regarding Power-Generating plants operating in parallel to the distribution network

At the time of issue of this certificate the safety concept of an aforementioned representative product corresponds to the valid safety specifications for the specified use in accordance with regulations.

  
**Name: Daniel Yu**  
**Manager / New Energy**  
**Date: 2024-07-24**

This document shall not be reproduced, except in full, without the written approval of Bureau Veritas Shenzhen Co., Ltd. Dongguan Branch.  
Information given in this document is related to the tested specimen of the described electrical sample.